Item #	MPL Outstanding Items List	Responsible Party	Date	Level	Room Number	Date Complete	Comments
1	Aluminum Parapet Cap Thermal Expansion Issue	DAC	13-Dec	L2-L4	Exterior		DAC will complete this work while on site for 4th Floor Patio Addition
2	Main Entrance Glass Vestibule Work	TC Glass	27-Apr	L1	107		Work is scheduled for the week of May 9th. We will hold a preconstruction meeting with all parties next week to review the plan.
3	Curtain Wall UV Transmittance	TC Glass	27-Apr	L1-L4			DAC will coordinate set up a meeting with all parties to review the response from the glass supplier
4	Failed Curtain Wall Glass at Climbing Structure	TC Glass	27-Apr	L1	106		TC Glass will replace this glass. Timeframe is still to be determined, we will discuss in next weeks meeting.
5	Continued Hardware. Storefront Framing Issues at Doors 405 & 411	TC Glass	27-Apr	L4	423		TC Glass is aware of this issue, they need to provide an update on it in the meeting next week.
6	Door 115 cylinder issues	TC Glass	27-Apr	L1	115		Staff door from Marketplace to hallway, by New Books – master key does not work or works poorly
7	Door 401A North Door	TC Glass	27-Apr	L4	401		Cooper Room A door – master key does not work or works poorly
8	Door 236	TC Glass	27-Apr	L2	236		Dooris jammed or seems stuck, making it difficult to open or close properly
9	Door 003	TC Glass	27-Apr	LL	003		Staff Elevator Vestibule Door rod continues to not retract which holds the door open, like the issues with the main entrance doors. See attached email for additional questions from the MPL.
10	Rooftop Patio Addition	DAC	27-Apr	L4	419		New work added. The plans are at the city for permiting. DAC is working on shop drawings/RFIs for steel